

Pay Energy once -

use it several times

Improvement of the energetic treatment situation with use of the exhaust air of the sewer system






Delegation travel Budapest 7.-9. September 2010

Scope:

- relay of the fossil fuel gas
- decline of CO₂ load
- liberation out of the central supply
- use of renewable energy trough innovative solutions





A alternative solution for the enregetic use of the sewer

- use of the energy source air -


- relatively constant air temperature of 12 to 15 °C will be influenced from the sewer amount just slightly
- high relativ air humidity
- both ideal circumstances. 10 Kelvin are available for the energetic use for the heat pump system
- use of fin heat exchanger (material V2A/V4A) big surface for the temperature intake because of that
- no contact with dirty water
- relativly low capital costs
- from sewage and channel environment heated air rises in the channel
- cooled air is specific heavier than the environment air at the channel, falls down on the sewage surface and will be evacuated in flow direction


Trademark rights are announced






Innovative use of energy from channel systems






Extraction of warmth


Bypass- solution for special physical conditions




Extraction of cooling temperature



Placement of Heat Exchanger





Technical data

Heat demand office building 30 kW heating

4 kW service water

Sewer DN 1000

Usable length approx. 400 Meter

Volume flow average 148.000 m³/ hour

at 0,2 till 0,8 m/ sec

Relativly humidity average 72%

Capacity of special heat exchanger

in the channel 34 kW


power consumption effective pump

for circuit bond system 130 Watt

Heat pump heating capacity 34 kW


Power consumption including heat pump 3 kW

COP heat pump at 45/ 40 °C 4,1



CO₂ saving

| Brennstoff Erdgas: | Heizwert | kWh/m³ | 10 | 10 | 10 | |
|---|-----------|-----------------------------------|---------|--------|--------|--|
| z.Zt. Benötigte Wärmemenge: | | kWh/a | 103.850 | 54.250 | 38.750 | |
| Emissionsfaktor CO ₂ - Erdgas | | kgCO ₂ /m ³ | 1,777 | 1,777 | 1,777 | |
| Vollnutzungsstunden | | Std | 1.550 | 1.550 | 1.550 | |
| vorhandene Leistung | | kW | 67 | 35 | 25 | |
| Volumen Erdgas / a | | m³/a | 10.385 | 5.425 | 3.875 | |
| z.Zt. Vorhandener CO ₂ Ausstoß | | kg/CO₂/a | 18.454 | 9.640 | 6.886 | |
| Einsparung mit Wärmepumpe: Annahme Stromerze | ugung mit | Erdgas | | | | |
| Einsatz Leistung WP | | kW | | 35 | 25 | |
| Cop | | W/W | | 5,6 | 5,6 | |
| Heiztemp. | | °C | | 35 | 35 | |
| elektr. Leistungsaufn. | | kW | | 6,3 | 4,5 | |
| Brennstoff Erdgas: | Heizwert | kWh/m³ | | 10 | 10 | |
| Vollnutzungsstunden | TICIZWCIT | Std | | 1.550 | 1.550 | |
| Wärmemenge /a | | kWh/a | | 54.250 | 38.750 | |
| elektr. Leistungsaufn. | | kWh/a | | 9.688 | 6.920 | |
| Emissionsfaktor CO ₂ - Strom bei Erdgas | k | g CO ₂ /kWh | | 0,662 | 0,662 | |
| CO ₂ Ausstoß | | kg/CO ₂ /a | | 6413 | 4581 | |
| Einsparung an CO ₂ | | kg/CO₂/a | | 3227 | 2305 | |
| | | | | | | |
| Einsparung an CO ₂ Einsparung an CO ₂ | | kg/CO₂/a % | | 3227 | 2305 | |



Thank you for your attention

Lindenstraße 5 09526 Olbernhau

Member of Management Volker Schubert

Tel: (037360) 69 49-0

Fax:(037360) 69 49-69

